

HVI Publication 920
2009 Rev. Edition
1 March 2009

This edition supersedes all previous editions.

HVI[®] PRODUCT PERFORMANCE CERTIFICATION PROCEDURE INCLUDING VERIFICATION AND CHALLENGE

This publication describes
the requirements and procedures for the
certified performance ratings program
for residential ventilation products
administered by The Home Ventilating Institute[®]



Home Ventilating Institute
1000 North Rand Road, Suite 214
Wauconda, IL 60084
USA

Phone: 847.526.2010
Fax: 847.526.2993
e-mail: cpd@hvi.org
Website: www.hvi.org

HOME VENTILATING INSTITUTE® PRODUCT PERFORMANCE CERTIFICATION PROCEDURE

The History of HVI®

The Home Ventilating Institute (HVI) was incorporated as a trade association in 1955. From the first, it has focused on residential ventilating products information for Members and consumers.

The History of HVI's Product Certification Program

HVI began to certify residential ventilation products' performance in the 1960's in response to a need for consistent and reliable information. Since the 1970's HVI has verified the performance of certified products independently procured from the marketplace. HVI's certification programs are continuously being refined. This edition of HVI 920 represents HVI's latest progress.

Disclaimer

Final recourse for consumers, competitors, Members and any other entity seeking any remedy for product certification and/or performance disputes is with the involved parties, not with HVI.

Units of Measure

Units of measure used herein are the inch-pound (IP) system because of present residential preferences. Values in IP units may be converted to the International System of Units (SI) units using conversions found in the ASHRAE Handbook of Fundamentals, chapter on Units and Conversions.

Related HVI Publications

- *HVI Publication 911: Certified Home Ventilating Products Directory* ©
- *HVI Publication 915: HVI Loudness Testing and Rating Procedure* ©
- *HVI Publication 916: HVI Airflow Test Procedure* ©
- *HVI Publication 925: HVI Label and Logos Requirements* ©

Blank Forms

Blank forms required for the HVI Certification process are available from HVI.

TABLE OF CONTENTS

1. Introduction, Basis, Purpose, Overview and HVI Label	3
2. Scope of This Publication.....	5
3. Definitions	5
4. General Certification Requirements	10
5. Procedure for Certifying Basic Model Numbers	15
6. Certifying Derived Model Numbers – Requirements and Procedures	17
7. Presenting HVI Certified Ratings – Form and Format.....	19
8. Record Keeping and Maintenance of HVI Certification Records	22
9. HVI Verification – Requirements and Procedures.....	23
10. HVI Challenge – Requirements and Procedures	29
11. Maintenance of HVI Publication 920	35
12. Appendix I. Product Categories, Tolerances, Requirements	37
13. Appendix II. Special Requirements – Exhaust Products.....	40
14. Appendix III. Special Requirements – Heat and Energy Recovery Ventilators.....	42
15. Appendix IV. Special Requirements – Combination Rating.....	47
16. Appendix V. Special Requirements – Static and Passive Vents.....	49
17. Appendix VI. Special Requirements – Integrated Supply and Exhaust Ventilators	50
18. Appendix VII. Special Requirements – Duct Termination Fittings.....	55

HOME VENTILATING INSTITUTE PRODUCT PERFORMANCE CERTIFICATION PROCEDURE

1. Introduction, Basis, Purpose, Overview, and HVI Label

- 1.1. Introduction. HVI Certification of product performance is a voluntary, cooperative, competitively policed program for obtaining, maintaining, and verifying performance ratings of residential ventilation products, and for presenting those ratings, administered by the Home Ventilating Institute.
- 1.2. Basis. HVI Certification is based on strictly specified product testing. It is maintained by the vigilance and quality control of HVI and each certifying Member.
 - 1.2.1. All product testing for HVI Certification is done in accordance with American National Standards Institute (ANSI) and Standards Council of Canada (SCC) consensus standards.
 - 1.2.1.1. HVI prescribes specific procedures for product testing within the ANSI standards.
 - 1.2.2. Testing for certification is done in an HVI designated third party laboratory; tests from Members' or other laboratories are not eligible for HVI Certification.
 - 1.2.3. Members apply to HVI for certification based on appropriate test reports. HVI reviews the application materials and grants certification if they are judged to be in accordance with HVI's prescriptive requirements, resulting in uniform and comparable ratings.
 - 1.2.4. The vigilance and quality control of every HVI Member enables them to be confident their products in the field will achieve their certified ratings.
 - 1.2.5. HVI's annual Verification Program enhances and strengthens the integrity of HVI Certification.
 - 1.2.6. The vigilance of every HVI Member, especially using the HVI Challenge procedure, ensures products will continue to perform as expected.
- 1.3. Purposes of HVI Product Certification.
 - 1.3.1. To provide uniform, comparable, and impartial HVI Certified performance ratings, in accordance with HVI procedures for testing, labeling and cataloging Member's products.

- 1.3.2. To enable designers, builders, consumers, code officials, and manufacturers, as well as Members, to confirm and compare ratings.
 - 1.3.3. To ensure users that HVI Certified products deliver the performance claimed.
 - 1.3.4. To ensure fair competition.
 - 1.3.5. To provide a readily available source of comparative data on residential ventilation products.
- 1.4. Overview of HVI Product Performance Certification. The program has four essential elements: Certification, Verification, Challenge, and Presentation of product performance ratings in the marketplace. Following are introductory overview descriptions of selected elements of HVI Certification, details of which are found in this and other HVI publications.
- 1.4.1. Certification is issued by HVI after a Member makes proper application, accompanied by a test report from an HVI designated third party laboratory, all as prescribed herein.
 - 1.4.2. The annual HVI Verification process requires random marketplace procurement by HVI of Certified products, with no participation by the Member. HVI provides the product to an HVI designated third party laboratory for testing to verify that HVI Certified products are continuing to deliver the expected performance. Procedures for resolution of any problems are described in this document.
 - 1.4.3. The HVI Challenge process enables one Member to question, with a basis, the published performance of another Member's HVI Certified product. HVI procures on the open market and tests the product (similar to Verification). Procedures for resolution are described in this document, and the loser pays HVI the costs of the Challenge.
 - 1.4.4. Presentation of HVI Certified product performance ratings in the marketplace is regulated to provide realistic and comparable ratings in HVI Members' collateral materials. Misrepresentation of product performance is prohibited.
 - 1.4.5. HVI publishes its Directory of Certified Products enabling easy product comparisons. Procedures and requirements for presentation of ratings are described herein.
- 1.5. The HVI Certification Label is required to be affixed to certified products in conjunction with the HVI Certified ratings, and in accordance with rules governing its use. See HVI Publication 925, HVI Label and Logos Procedure.

2. Scope of This Publication

- 2.1. This procedure covers certification of residential (home) ventilation products for which HVI has adopted a certification program.
- 2.2. This procedure covers those product performance parameters (including, but not limited to airflow, sound level, and energy performance) for which HVI has adopted a certification program.
 - 2.2.1. Not all parameters are certified for all products. Products, for which HVI has adopted a certification program, and the specific parameters and requirements for those products, are listed in the Appendices.
- 2.3. The elements of HVI product certification are described in this publication to ensure consistent, fair and equitable administration of the program.
- 2.4. This document describes the HVI Certification program requirements. It is arranged in an explanatory manner to assist HVI Members participating in the programs, and for the information of those who depend on the ratings.
- 2.5. This procedure refers to product testing in general language. For specific test methods and requirements, refer to the applicable HVI publications and their related test procedures. Information more specific to product categories adopted by HVI can be found in the appendices of this publication.

3. Definitions

- 3.1. Airflow rating - Quantity of airflow a product will produce at the specified rating point static pressure, measured in cubic feet per minute (cfm).
- 3.2. Basic model (or base model) - The model initially certified, from which certification for other models may be derived. (See also Derived model.)
- 3.3. Blending ventilator – Ventilator that mixes two or more airflows for distribution throughout the house. (See also Integrated supply and exhaust ventilator.)
- 3.4. Cfm – Cubic feet of air per minute, ft³/min, at 0.075 lb/ft³, HVI's "standard" density. The unit of measure for airflow ratings.
- 3.5. Derived model – A model whose certification is derived from another (basic) model. (See also Basic model.)
- 3.6. Direct discharge fans – Exhausters that mount in an exterior wall, discharging air directly to the outdoors without ductwork.

- 3.7. Ducted products – Ventilating products that utilize ductwork to move air between the indoors and outdoors.
- 3.8. Family of products – A group of products that include one basic product and one or more derived products that all depend on a common certification test. (See also Basic model, and Derived model.)
- 3.9. HVI Certified Home Products Directory (or HVI Directory) – Official HVI publication of certified product ratings. The HVI Directory can be an annual directory, a supplement, and/or a monthly HVI website directory.
- 3.10. HVI Certified Ratings – Performance ratings, based on prescribed and controlled testing of certified products, that the HVI Member is confident its certified product will achieve if picked up in the field and tested in accordance with verification procedures at an HVI designated laboratory.
- 3.11. HVI Member (or Member) – An organization (business) that has met all requirements for HVI membership and has been accepted into the membership (see HVI Bylaws). For HVI product performance certification, there is provision for non-Member participation (see Section 4 of HVI 920).
- 3.12. Indoor duct inlet – A duct termination fitting, mounted inside the building structure, which is used to remove air from a room or other space.
- 3.13. Indoor duct outlet – A duct termination fitting mounted inside the building structure, which is used to introduce air into a room or other space.
- 3.14. Net free area, tested – Net free area of a static ventilating device based on an actual airflow test of the product in accordance with the HVI procedure listed in Appendix V.
- 3.15. Normalized airflow curve – An airflow curve that precisely represents a product's airflow performance relative to the basic static pressure rating point. A normalized curve is used for ratings in addition to the basic rating point. It is developed by applying the Normalized Curve Ratio to the airflow test curve. See Appendix I for details. (See also Normalized curve ratio).
- 3.16. Normalized curve ratio (NCR). The ratio between the airflow performance rating and the tested airflow performance, both at the basic static pressure rating point, used for a normalized airflow curve. The NCR is always less than or equal to unity.
- 3.17. Outdoor duct inlet – A duct termination fitting, intended to be mounted on the exterior of the building structure, that is used for the introduction of outside air into the building.

- 3.18. Outdoor duct outlet – A duct termination fitting, intended to be mounted on the exterior of the building structure, that is used to exhaust air to the outside. Included are wall caps, roof caps, and eave caps.
- 3.19. Pressure, static (P_s) – The air pressure that a fan must overcome in order to produce an associated airflow. The static pressure rating point (or points) is the nominal amount of static pressure adopted by HVI for rating the airflow of a given product category (see appendices).
- 3.20. Probationary model or product (probationary ratings) – A model that originally had HVI Certified ratings, but failed an HVI verification or challenge test. Provisions regulating probationary models are described in other sections of this procedure.
- 3.21. Product categories – The standard HVI names for product types or product-line groups, used for the HVI Directory, product comparisons and certification rules. For further information on product categories, see Appendix I. Product categories are defined as follows:
- 3.21.1. Bathroom exhaust fan – A fan primarily intended for exhausting air from a bathroom.
 - 3.21.2. Bathroom combination unit – A bathroom exhaust fan that includes other function(s), such as lighting and/or heating.
 - 3.21.3. Downdraft kitchen exhauster – A ducted exhauster located adjacent to the cooking function at or near countertop level, sometimes integral with the range. A downdraft kitchen exhauster has an air inlet for removing and exhausting cooking contaminants. A downdraft kitchen exhauster utilizes a relatively high volume of air to capture contaminants by velocity. Includes non-powered downdraft kitchen ventilator.
 - 3.21.4. Duct termination fitting – A ducted fitting mounted at the end of a duct, including indoor duct inlets and outlets and outdoor duct inlets and outlets.
 - 3.21.5. Energy recovery ventilator – A mechanically powered ventilating device with separate intake and exhaust air streams, and a heat exchanger to transfer a portion of the total energy (heat and moisture) from one air stream to the other.
 - 3.21.6. Fresh air inlet – A passive opening to the exterior of a structure that is used for the introduction of outside air into the living space.

- 3.21.7. Heat recovery ventilator – A mechanically powered ventilating device with separate intake and exhaust air streams, and a heat exchanger to transfer a portion of the sensible energy (heat) from one air stream to the other.
- 3.21.8. Inline fan – A fan designed to be located within the building structure with ductwork on both intake and exhaust.
- 3.21.9. Integrated supply and exhaust ventilator – A ventilating device with both exhaust and supply systems that mixes the fresh air with a certain amount of recycled air. Sometimes called a balanced ventilator.
- 3.21.10. Kitchen fan – A ceiling or wall mounted, ducted or direct discharge, exhaust fan for exhausting contaminants from a kitchen.
- 3.21.11. Kitchen range hood – A ducted exhauster for use over cooking equipment that captures contaminants by buoyancy and exhausts them. May be a dual-function appliance, incorporating microwave, and/or clock function, for example. Includes non-powered kitchen range hoods. Ductless range hoods are excluded.
- 3.21.12. Other room exhaust fan – An exhaust fan for mounting in the ceiling or wall of any room. The fan may or may not be suitable for use in a kitchen.
- 3.21.13. Non-powered kitchen ventilator – A kitchen ventilator without an air-moving device, intended for use with a separate power unit. Included are standard (catalogued) range hoods, specialty range hoods, and downdraft kitchen ventilators. The non-powered kitchen ventilator and separate power unit may or may not be offered by the same manufacturer.
- 3.21.14. Power attic ventilator (PAV) – An exhaust fan intended to remove air from an unoccupied attic.
- 3.21.15. Range hood power unit – An interior power unit offered separately for use with a non-powered kitchen ventilator.
- 3.21.16. Remote exterior mounted ventilator – An exhaust fan intended for mounting in an exterior location, usually connected by ducts to an interior device such as a downdraft intake, a range hood shell, or a grille.

- 3.21.16.1. “Type B” remote exterior mounted ventilator – An exhaust fan which is used as a year-round low velocity whole house ventilation system. The fan is usually mounted on the roof and is ducted to an air intake grille at the ceiling. For purposes of distinguishing this product from other remote exterior mounted ventilators, HVI refers to this product as a “Type B” remote exterior mounted ventilator throughout its procedural publications including HVI Publication 915, 916 and 920. No product distinction is made in the HVI Certified Products Directory.
- 3.21.17. Separate interior power unit – An air-moving device offered for kitchen ventilation in connection with a non-powered kitchen ventilator. The standard HVI name for this category is range hood power unit.
- 3.21.18. Separate power unit for kitchen ventilation – A power unit offered separately for use with non-powered kitchen ventilators. The power unit may be a remote exterior mounted ventilator, range hood power unit, or inline fan, any of which may be offered for kitchen ventilation. The separate power unit and non-powered kitchen ventilator may or may not be offered by the same manufacturer. The definition does not include separate power units that are not offered for use in kitchen ventilation applications, even though they may be similar.
- 3.21.19. Static vent – A non-powered ventilating device intended to allow or provide airflow for attic, crawl space and other building structural spaces.
- 3.21.20. Whole house comfort ventilator – A ceiling mounted exhauster that moves relatively large volumes of air into the attic, drawing intake air through open window(s) to provide increased comfort through velocity cooling.
- 3.22. Residential (home) ventilation – Mechanical ventilation serving residential dwelling units (homes), as opposed to commercial, industrial, or institutional buildings. Residential ventilation, with few exceptions, serves a single dwelling unit, whether it is in a single family or low- or high-rise building.
- 3.23. Sone – A unit for rating sound level that is linear and weighted to represent the response of the average human auditory system.
- 3.24. Testing laboratory, HVI-designated – An independent third party laboratory that has been designated by HVI to perform product testing for certification, verification and challenge. A list of HVI-designated laboratories and the product categories and procedures for which they are authorized to conduct HVI testing is available on the HVI website or by contacting HVI headquarters.

4. General Certification Requirements

- 4.1. HVI product performance certification begins with standardized testing in accordance with HVI procedures using the most precise and repeatable methods available for the type of products involved. Testing is based on methods described in consensus-based testing Standards, carried out under narrowly prescribed testing procedures at an HVI designated third party laboratory. For details, refer to other HVI Publications and the standards on which they are based.
 - 4.1.1. When a model number is to be HVI Certified for more than one parameter such as air and sound, a single product shall be used for all certification testing and no alterations between tests is permitted.
- 4.2. Members may apply for HVI Certified performance ratings when confident the product will pass HVI verification testing. (See Section 9, HVI Verification.) This requirement is fundamental and applies to all aspects of the program, including basic model certification, derived model certification, product modifications and presentation of product performance ratings.
- 4.3. HVI Certification is appropriate for standard, commercially available, residential ventilation products with brand names and model numbers. HVI Certified products are usually produced in volume and are offered in printed literature under a specific brand name and model number.
- 4.4. HVI Certification relies primarily on simplified single number ratings that may be insufficient information for designers who plan to incorporate a certified product into a complex non-residential system.
- 4.5. HVI Certification is not appropriate for custom-made, one-of-a-kind, or commercial / industrial products. Other organizations administer programs for this class of products.
- 4.6. Both HVI Certified ratings and licensed ratings from other certifying organizations may be presented on the same page, sheet or publication, as long as it is clear which ratings are certified by HVI.
- 4.7. HVI Members who certify at least one model in a product category shall certify all models in the category. Selective HVI Certification of models in a product category will not be issued by HVI.
 - 4.7.1. "Category", above, refers to the standard HVI categories listed in HVI 920, Appendix I.

- 4.7.2. A Member has one year from certification of the first product in a Product Category to complete the certification of all products in that category. If a Member has justifiable reasons to extend this period, or to be allowed exemptions from the requirement to certify all models in a category, the Member may apply to the Board for special permission. Examples of such justifiable reasons include laboratory limitations or a large offering to be certified in a category by the Member.
- 4.7.3. The requirement to certify all products in a product category only applies to mandatory ratings. Optional ratings may be certified selectively.
- 4.8. HVI Certified products shall be certified for sound performance, unless no sound certification procedure presently exists for that product category.
- 4.9. HVI Certified products rated at more than one static pressure point shall be HVI Certified for sound performance at each point (if sound certification is available for the product category). (For particular requirements for specific product categories, see the appendices to this procedure.)
- 4.9.1. Exception: When additional airflow ratings are based on the HVI Normalized Curve procedure, HVI sound certification is not required for the additional airflow ratings. If included, additional sound ratings shall be HVI Certified.
- 4.10. Products with selectable discharges (e.g., vertical and horizontal) shall be rated for every discharge possibility.
- 4.11. Multiple speed products' basic ratings shall be at maximum speed; ratings at other speeds are optional. (See also specific requirements and exceptions in appendices.)
- 4.12. At the Member's option, electrically operated HVI-Certified products may also be certified for energy required to operate them (designated as Energy to run fan); requirements are described herein. Energy used for lights, sensors, heaters, timers, or night lights is not included in the determination or power consumption. This is not to be confused with energy recovery products, for which energy certification is mandatory.
- Section 4.12.1.
- 4.12.1. Energy to run fan (watts) for specific products must be certified and published in the HVI Certified Products Directory to maintain eligibility for the Energy Star.
- 4.13. Specific requirements for product categories are found in the applicable appendices of this publication.

- 4.14. Whenever an HVI Member decides to apply for a new certification for a product using the same model number as a previously certified product, the Member shall explain in writing to HVI how to differentiate between obsolete and current stock, so HVI is able to procure the latest version. This requirement applies for any such situation whether it is the result of verification or challenge or a product design change.
- 4.15. Modification of a model number, including any change or substitution (e.g., of components or configuration) that will adversely affect the HVI Certified performance, requires that the product be re-tested and re-certified. It is the Member's responsibility to evaluate and control changes that affect the Member's confidence in every HVI Certified performance parameter.
- 4.16. A Member may make application for certification of a "derived" model, basing the request on the test and ratings of a certified "basic" model. (See Section 6, "Certifying Derived Products" for requirements and procedures.)
- 4.17. Safety Listing. HVI Certified products shall be listed or certified for safety with a recognized laboratory if an applicable program exists for the category.
- 4.18. HVI Label and Ratings Markings. The HVI Certified Label shall be affixed to all HVI Certified products, and the HVI Certified ratings shall appear in conjunction with it. See HVI Publication 925, HVI Label and Logos Requirements, for details regarding the HVI Certified Label and its use.
- 4.19. HVI Certified ratings shall be in a manner consistent with HVI requirements wherever presented, including catalogs, website and literature. Catalog approval by HVI is not required before printing, but HVI welcomes requests for assistance in meeting HVI's ratings presentation requirements.
 - 4.19.1. HVI shall enforce presentation of HVI Certified ratings in catalogs and literature. Enforcement shall be of a helpful nature, but if results are not forthcoming, and/or if the Member is not responsive, HVI shall protect its certified ratings program through increasingly rigorous measures.
- 4.20. If a Member misrepresents a product's certified ratings in its literature, or abuses HVI Certification through its marketing or sales collateral, website or promotions, HVI can require the Member to cease distribution of such literature and information, and/or require the Member to correct such misrepresentation.

4.21. Every HVI Certified product shall have a production date code. The date code is usually the same one as safety listing organizations already require on every product. HVI shall verify compliance with this provision and remind and/or enforce it at appropriate opportunities including verification and challenge.

4.21.1. If there is a question of when a product was produced, such as in connection with a Verification or Challenge, the date code on the product shall be used to determine date of manufacture by HVI and by competing Members.

4.21.1.1. If the Member's date code is in a cryptic style that would defeat the intent of this requirement, the translation of the code shall be provided to HVI for the product and period in question.

4.22. The HVI Normalized Airflow Curve is a standard method of representing an HVI Certified product's airflow performance at static pressures in addition to the standard static pressure rating point for the category. Due to HVI-prescribed rounding, the test report airflow curve must be "normalized" for it to agree with the HVI Certified rating(s). For a description of the procedure for development of an HVI-acceptable normalized airflow curve, see Appendix I. The normalized airflow curve has several purposes including those described below.

4.22.1. First, when a product has more than one HVI Certified airflow rating point, either required or optional, the first (basic) rating point may generally be used to create a normalized airflow curve, and it becomes the source of additional ratings. (See appendices for product categories that permit or prescribe more than one rating point, and those that require testing rather than the Normalized Curve.)

4.22.2. Second, a Member may wish to publish an airflow curve based on the certification test, in addition to the HVI prescribed single number rating(s). The resulting normalized airflow curve is not HVI Certified, but is constructed in accordance with HVI procedures, and is in agreement with the HVI Certified Rating(s).

4.22.3. Third, special rating points may be required for unique jurisdictions that require rating at other than the prescribed HVI static pressure. For those, HVI Members may obtain HVI Certification and present unique ratings in addition to those prescribed herein by following the normalized curve procedure in Appendix I.

- 4.22.3.1. It is optional but not required that such unique ratings be displayed in conjunction with the label, on the product, in the literature, or on the carton. Members may issue published supplement(s) presenting unique HVI Certified ratings.
- 4.22.3.2. Such ratings may appear in the HVI Directory, at the Member's request, and are subject to HVI Verification and Challenge.
- 4.23. The HVI Directory is HVI's instrument for publishing all current certified product ratings. HVI shall publish monthly updates to current ratings in its website Directory on the internet.
- 4.24. Confidentiality shall not be breached by any participant in any HVI Certification activity in any manner that would create a market advantage or disadvantage for any Member or downstream supplier, except as described as a normal part of the program.
- 4.25. HVI shall publish all certified ratings as soon as practical after issuance, but not before the date requested by the Member. A product becomes certified when HVI publishes its ratings. If queried, HVI shall provide certified ratings, and whether they are current, valid, and in good standing. HVI shall not release any other information about any product's certification without the Member's consent.
- 4.26. In the event there is a disagreement related to any aspect of the HVI product certification program, the HVI Board of Directors will intervene and dictate fair and equitable resolution. They may decide to require a meeting with the certifying Member or any other Member.
- 4.27. Any failure to follow the requirements of any part of the HVI Certification program requires that HVI administration report the details and problems to the HVI Board of Directors. They shall take appropriate corrective action, possibly including expulsion and/or a report of the problems and actions to the full HVI membership.
- 4.28. This procedure is not intended to exclude non-members from participating in HVI product performance certification. To participate, a non-Member is required to meet certain appropriate participation criteria intended to protect and preserve the value and integrity of the HVI Certification program and to enable HVI enforcement for those reasons. General steps for non-Member product certification are listed below; the steps may be modified as appropriate for each case.

- 4.28.1. The applicant must demonstrate that it meets relevant HVI membership criteria as defined in the HVI Bylaws, including particularly the following:
 - 4.28.1.1. The applicant must be a company engaged in marketing and selling complete residential ventilation products under its trade name(s) in the United States and/or Canada.
 - 4.28.1.2. The applicant must have control over the design or manufacture of the products.
- 4.28.2. The applicant shall request a Non-Member Certification Agreement from HVI.
- 4.28.3. After investigation with respect to the criteria, vote of approval by the HVI Board, execution of the Non-Member Certification Agreement by both parties, and payment of an initial fee, the applicant is an “authorized company” and may apply for HVI Certification of its products.
- 4.28.4. Wherever this Procedure uses the term “Member” or “HVI Member” it is understood to include an authorized company as described above.
- 4.28.5. The published HVI fee schedule for certification by an authorized company is different (higher) than for Members.
- 4.28.6. Authorized companies shall meet all certification requirements, including ratings presentation and certification of all products in a product line (See Section 4).
- 4.28.7. HVI shall enforce certification requirements consistently and fairly for authorized companies as well as HVI Members.

5. Procedure for Certifying Basic Model Numbers

- 5.1. Testing. The Member shall arrange for testing as described below.
 - 5.1.1. Preparation. Preparation of a product for testing may include certain mountings, etc., as described in the HVI test procedures. The product shall not be specially prepared or tuned because ratings represent performance of production products.
 - 5.1.2. Submittal. HVI Members shall submit the product to an HVI designated testing laboratory for HVI product certification testing. The HVI Member shall designate the desired tests and the ratings that the Member expects to certify.

- 5.1.2.1. An HVI designated testing laboratory will require various forms such as test submittal data sheet and testing agreement or contract. (The required blank forms and assistance completing the forms is available from HVI and each HVI designated laboratory.)
- 5.1.3. Laboratory testing. The HVI designated laboratory shall test in accordance with the current HVI test procedure publications and their foundational standards.
- 5.1.4. Test Report. The laboratory shall furnish the Member a copy of a test report that includes the model number of the product tested, performance data, sufficient photographs to document the test set-ups, and any other item appropriate to the product and test.
- 5.1.5. Fees for testing. Fees for product certification testing are to be paid directly to the testing laboratory by the Member requesting the testing. Laboratory testing fee schedules are negotiated by HVI from time to time and a copy of the current fee schedule is available from HVI.
- 5.2. Application for certification. The Member who submitted the product for testing will submit the following items to HVI in application for certification.
 - 5.2.1. A copy of the complete test report, including sufficiently clear copies of the photographs to document the test setup.
 - 5.2.2. A completed Request for HVI Certification of a Product. (The blank form is available from HVI.)
 - 5.2.2.1. Information required includes the name of the company requesting certification, the brand name of the product, the model number of the product, the test report identification number and date, the specific performance certification ratings requested for all applicable parameters, and the earliest date the Member wishes HVI to communicate the ratings. See appendices for product- and parameter-specific requirements. An updated base and derived spreadsheet for the category(s), showing the model for which certification is requested, shall be included.
 - 5.2.3. Sales literature, or product specification sheet, describing the product tested (may be submitted later if not available at the time).
 - 5.2.4. Evidence of listing by a safety agency (such as Underwriters Laboratories).

- 5.2.4.1. Because of sequence, safety listing may not be available at the time HVI Certification is requested. HVI administration is not required to withhold initial certification for failure to provide proof of listing. On the other hand, HVI shall verify safety certification whenever a product is picked up in the field for verification or challenge. HVI may verify safety listing or certification by calling the safety agency for confirmation at any time.
- 5.3. Issuance of certification. HVI will review the materials submitted and if all requirements have been met, and if everything is in order, will issue the signed HVI Product Certification form to the Member.
 - 5.3.1. Communication and publication of certified ratings. After issuing the certification, and after the Member-requested earliest date, HVI is free to communicate the certified ratings. HVI will publish them in the next Directory and website Directory.

6. Certifying Derived Model Numbers – Requirements and Procedures

6.1. Requirements

- 6.1.1. A Member may make application for certification of a "derived" model, basing the request on the test and ratings of a certified "basic" model for which the Member already holds HVI Certification.
 - 6.1.1.1. Models that have a basic and derived relationship because their HVI Certification is based on the same test report are called a "family" of products in this Procedure.
- 6.1.2. The derived model may be certified if it only differs from the basic model in aspects which do not adversely affect the product's HVI Certified performance ratings, such as color, finish, name plate, or other similar variances. As with all certification, the Member's confidence in the model's performance is required.
- 6.1.3. Derived model certification shall not be used to avoid testing products that differ significantly from the basic product.
- 6.1.4. Performance, test, and rating representation issues with one model number in a family of model numbers shall result in the appropriate effect for the entire family because one test is the basis of the entire family's certification. (i.e., references to a model number within this procedure, including verification and challenge, apply to its entire family.)

- 6.1.4.1. In the specific case of a failed verification or challenge test resulting in withdrawal or re-certification of the failed model number or its ratings, the entire family shall be withdrawn or must be re-certified.
 - 6.1.4.1.1. Exception: If a de-rated derived product passes verification or challenge tests, but test results would not be passing for other models in the family that are not de-rated, those other model numbers shall not be considered to have failed unless they do not meet their specific HVI Certified rating. Those other models may be subjected to a verification test. (Exception: ERV and HRV, see Appendix III.)
 - 6.1.5. An HVI Member may make application for certification of a derived product for another HVI Member based on the first Member's basic product. (Private label certification is permitted.)
 - 6.1.6. An HVI Member may make application for certification of a derived product for a non-Member based on the Member's basic product. The Member then assumes responsibility for any problems and enforcement. Non-Member private label certification is permitted under the Member's control.
 - 6.1.7. Application for private label certification is always the responsibility of the Member responsible for the basic product.
 - 6.1.8. The Member or non-Member desiring the derived private label certification will create a letter to HVI stating that they desire the certification. The letter will be delivered to the Member responsible for the basic product who shall include it with the application for HVI Certification.
- 6.2. Procedure
- 6.2.1. Certifying a derived product follows a procedure similar to certifying a basic product, with variations described in this Section. A Member shall submit a Request for Product Certification to HVI as described in Section 5, Basic Model Number Certification.
 - 6.2.1.1. All certification information about the basic product is required, including brand name, model number, test report date and number. A copy of the test report, already on file at HVI, is not required. An updated base and derived spreadsheet for the category(s), showing the model for which certification is requested, shall be included.

- 6.2.1.2. The Member shall describe in writing to HVI the difference between the derived model number and the basic model number, all in confidence.
- 6.2.2. HVI administration shall review the request and its attachments and evaluate the described differences between the basic and derived products.
 - 6.2.2.1. If HVI's review finds that the basic model and the derived model have no inappropriate differences, the basic model is in good standing, and all submittal materials have been received, they shall issue the signed HVI Product Certification for the derived model to the Member.
 - 6.2.2.2. If the evaluation of the described differences between the basic product and the derived product causes HVI to be concerned that the difference may have a negative effect on performance, HVI shall request appropriate action from the Member before issuing HVI Certification. The requested action may include furnishing HVI with inspection models or a proof test of the derived model.
- 6.2.3. HVI shall issue the HVI Product Certification for the derived model in the same way it issues it for basic models, after everything is in order.

7. Presenting HVI Certified Ratings – Form and Format

7.1. General Requirements

- 7.1.1. HVI Certified Ratings shall be presented as prescribed below wherever the ratings are presented, including on products, packaging and associated literature.
- 7.1.2. Rounding to the nearest . . . follows conventional practice, i.e., 5 or more rounds up. Thus, when rounding to the nearest half sone, 2.74 rounds down to 2.5, and 2.75 rounds up to 3.0 sones.
- 7.1.3. This section describes general requirements. Particular requirements for each product category are found in the applicable appendix. Appendix I contains a guide to the proper appendix for each product category.

- 7.1.4. Consistency of HVI ratings between categories is a primary objective; therefore, differences between product categories must be logical and explainable. Nevertheless, functional differences exist between categories. If there is a conflict between this section's requirements and those in the category's appendix, the appendix shall take precedence.
- 7.1.5. See Appendix I for conversion of units of measure between IP and SI units.

7.2. Airflow ratings

- 7.2.1. Shall be expressed in cfm, in whole numbers. See Appendix I for SI units.
- 7.2.2. Shall be rounded down to the nearest 10 cfm. (Varies for certain categories; see appendices.)
- 7.2.3. In case more than one rating is to be certified by HVI, the basic rating shall be rounded down to the nearest 10 cfm as indicated, and additional rating points shall be derived from a normalized curve to the nearest whole number. (See "normalized airflow curve" in General Certification Requirements section, and Appendix I.)
 - 7.2.3.1. Exception: Duct termination fitting rating points shall be derived from the test airflow curve, rounded down to the nearest whole number.
- 7.2.4. Presenting ratings. For those products with more than one HVI Certified airflow rating point, each rating point shall be identified by expressing its static pressure (P_s) in inches wc. Products with a single rating point may list the static pressure along with the airflow rating. (See Appendix I for SI units.)

7.3. Sound (loudness) ratings

- 7.3.1. Shall be expressed in sones, using one decimal place (e.g., 3.5 sones).
- 7.3.2. Greater than 1.5 sones shall be rounded to the nearest 0.5 sone.
- 7.3.3. From 0.3 sones to and including 1.5 sones shall rounded to the nearest 0.1 sone.
- 7.3.4. Less than 0.3 sones will be rated <0.3 sones, because sound testing resolution is inadequate to differentiate more finely at lower levels.

- 7.4. Energy Ratings (For Energy to Run Fan – for energy recovery products see Appendix III.)
- 7.4.1. Shall be expressed in watts using three significant digits (e.g., 21.3 watts, 213 watts). Watts ratings under 10 shall be expressed with two significant digits instead of three.
 - 7.4.2. Shall be rounded up to the third digit.
 - 7.4.3. Cfm/Watt may also be expressed in Members' literature, provided it is based on a direct calculation of HVI Certified Watts and cfm, using data from the airflow test report at the rating point. Cfm/Watt is not an HVI Certified parameter, but the HVI standard procedure for presenting cfm/watt is to round to the nearest one decimal place (tenth).
- 7.5. Energy Recovery ratings
- 7.5.1. See Appendix III.
- 7.6. Net free area ratings:
- 7.6.1. See Appendix V.
- 7.7. De-rating. Any Member company may apply for a lesser performance rating than is shown on the test submitted with the application for certification. The Member is required to have confidence the product will meet the ratings.
- 7.7.1. HVI airflow certification ratings may be less than shown on the test report; airflow ratings shall still be in 10's of cfm as in 7.2.2. (Varies for certain categories; see appendices.)
 - 7.7.2. HVI sound certification ratings may be more than shown on the test report.
 - 7.7.3. HVI Energy to run fan(s) certification ratings may be more than shown on the test report.
 - 7.7.4. HVI Energy Recovery certification ratings may be less than shown on the test report.
 - 7.7.5. HVI Net Free Area certification ratings may be less than shown on the test report.

- 7.7.6. HVI Certified performance ratings of derived products may be de-rated from the HVI Certified performance ratings of the basic product, or a basic product may be de-rated while a derived product is not. Regardless, each Member of a “family” must pass HVI Verification and Challenge, based on the HVI Certified rating for that model number.
 - 7.7.6.1. Basic and derived products must be equivalent in design and construction as described in Section 6, Certifying Derived Model Numbers.
- 7.7.7. De-rating shall not be used to avoid testing derived models that are not the same as described in Section 6, Certifying Derived Products.
- 7.7.8. HVI Certification is based on “single number” ratings for most products. A full fan performance curve based on HVI Certification testing may be presented in a Member’s literature and/or website. The curve is not HVI Certified. (See also 4.22.2.)
 - 7.7.8.1. HVI has no routine procedure for enforcing the accuracy of these curves. Nonetheless, HVI may become involved as per Par. 4.26 and 4.27 if it receives an inquiry about possible inconsistency; HVI shall not permit misrepresentation of data related to HVI Certification and shall protect its certified ratings program.

8. Record Keeping and Maintenance of HVI Certification Records

- 8.1. HVI shall maintain a file on each product it certifies. The file shall contain all items related to the product’s certification, including a copy of the test report (except for derived products), the Request for HVI Certification of a Product with attachments, and information documenting the history of all verification and challenge activity related to the specific model number.
- 8.2. Each Member shall maintain a similar file on its premises.
- 8.3. Either HVI or the Member may call upon the other to help maintain records, furnish missing copies, etc.
- 8.4. Each Member that has derived or private label models shall furnish HVI a spreadsheet showing product ratings, identification data, test identification and the relationship between Basic and Derived models. The HVI Base and Derived Spreadsheet is available from HVI.
 - 8.4.1. Any change in a Member’s certified product listings requires a new Basic and Derived Spreadsheet for the product category.

- 8.5. HVI shall retain a current Basic and Derived spreadsheet for each certifying Member with derived products.
- 8.6. HVI shall compare information with the Member from time to time to verify consistency of record keeping.
- 8.7. Upon request from a Member competing in the same category, HVI shall make a certifying Member's product family information available to the competing Member.
 - 8.7.1. Sharing basic-and-derived family information shall be limited to situations where it is not possible to identify clearly which family a certain product belongs to, and/or to identify all members of the family.
 - 8.7.2. Sharing basic-and-derived family information shall be limited to one product family per request.
- 8.8. When a file is no longer active because a Member dropped a product, stopped doing business, etc., such files shall be retained by HVI a minimum of three years.
 - 8.8.1. Exception: When the product is a basic model that other models derive their certification from, the file shall be retained by HVI a minimum of three years after all models in the family have been dropped.

9. HVI Verification – Requirements and Procedures

- 9.1. Verification Requirements
 - 9.1.1. Verification is required by HVI to assure and demonstrate the continuing validity of HVI Certification. Verification does not replace Challenge; the two procedures are complimentary in support of HVI Certification.
 - 9.1.2. When an HVI Certified product is selected for verification, all certified ratings shall be verified.
 - 9.1.3. HVI shall conduct at least one verification cycle each year. See Appendix I for the proper verification year for each category.
 - 9.1.3.1. During even numbered years, one model shall be tested from each Member's product category groups including the following: bathroom fans, downdraft kitchen exhausters, integrated supply and exhaust ventilators, other room exhaust fans, fresh air inlets, and static ventilators. (See Appendix I for complete list of categories and for category groupings.)


- 9.1.3.2. During odd numbered years, one model shall be tested from all other product category groups of each Member, including: duct termination fittings, powered attic ventilators, whole house comfort ventilators, remote exterior mounted ventilators, heat (and energy) recovery ventilators, inline fans, kitchen fans, kitchen range hoods, power attic ventilators, and range hood power units. (See Appendix I for complete list of categories and for category groupings.)
- 9.1.4. In addition to annual verification, HVI shall conduct special verification when HVI deems it necessary to demonstrate the continuing validity of HVI Certification, or to uphold or enforce the HVI Certification programs. Such verification will usually, but not necessarily, be focused on an area where there is reason to be concerned (e.g., a certain product category, a certain Member or Members, and/or products that have undergone certain changes). Such special verification requires the approval of the HVI Board.
- 9.2. Procedure and schedule for normal HVI verification. The following procedure is to be followed annually on approximately the schedule described.
 - 9.2.1. The HVI verification timeline is shown as a chart at the end of this section. In addition, special requirements for HRV and ERV Verification are found in Appendix III.
 - 9.2.2. By March 1: HVI requests from each certifying Member the names and locations of at least six of its outlets where all its certified products may be procured. (It may be necessary for a Member to provide more than six outlets in total, identifying the products or categories available in each.)
 - 9.2.3. By March 15: Each Member responds, in confidence, to the request. The choice of location should be based on broad offerings, reliable stocking conditions, and convenience to the HVI office.
 - 9.2.4. By April 1: HVI staff randomly selects the models to be tested from current HVI Certified Products Directory. For each test, HVI selects three models, designated as follows: a) preferred model, b) first alternate, and c) second alternate.
 - 9.2.5. By May 30: HVI procures the selected model(s) from one or more of the outlets, or other location it may choose. HVI pays for all products procured.

- 9.2.5.1. HVI has the test products delivered to the designated test laboratory as they are received. The products shall be identified as verification units and, for products with optional-discharge (e.g., vertical and horizontal) ratings, HVI shall randomly select and inform the lab which discharge is to be tested.
- 9.2.6. Between June 1 and August 31, the designated laboratory tests all units submitted, completing a test report for each one. Test procedures are the same as for initial certification (including accessories, test points, and set-up) except as follows:
 - 9.2.6.1. Test witness shall not normally be permitted. (Exception: See Appendix III.)
 - 9.2.6.2. A sufficient number of photographs to demonstrate test set-ups shall be taken.
 - 9.2.6.3. Range hoods and other products with optional (e.g., vertical or horizontal) discharges will be tested using the one designated by HVI.
 - 9.2.6.4. Sound tests will require careful test laboratory set-up because the Member will not be mounting the product on the test ceiling panel.
- 9.2.7. By September 30: HVI will analyze the test reports for pass/fail, in accordance with tolerances listed in the Appendix. The basis for analysis is the certified rating, not the initial test report. HVI will notify the Member, enclosing a copy of the test report.
 - 9.2.7.1. If the product passes, no further action is required.
 - 9.2.7.2. If the product fails, all of its ratings are classed "probationary" and they must be resolved. If the failed model number is a Member of a basic and derived product family, all members of the family are probationary.
 - 9.2.7.2.1. Even though probationary, for 90 days HVI shall answer inquiries with the regular ratings and not publicly reveal their probationary status, nor change the Directory. The period of time is consistent with the 90 days the Member is given to describe corrective action (below).
- 9.2.8. Resolving failures in normal verification. Within 30 days of receiving notice of a test failure, the Member shall respond describing to HVI the corrective action selected. Options available to the Member include the following:

- 9.2.8.1. Request that HVI procure and test another unit. (Exception: See Appendix III.)
- 9.2.8.2. The Member may submit a new Request for HVI Certification of a Product, with a new test report and all other attachments, requesting a new certification for the probationary model. In addition, the Member is required to inform HVI how to tell the difference between old and new products on the outside of the carton so that new products may be procured.
 - 9.2.8.2.1. HVI may decide to conduct immediately a special verification of the newly re-certified model.
- 9.2.8.3. The Member may immediately accept the verification test data and request the product be certified at those ratings (appropriately rounded and presented).
- 9.2.8.4. The Member may immediately withdraw the model from the market.
- 9.2.8.5. The Member may submit to HVI a "plan of action" for correcting the model. The Plan shall describe the actions the Member will take to get the product into compliance within no more than 60 days.
 - 9.2.8.5.1. The plan of action shall be reviewed by HVI to determine that it can be reasonably expected to correct the problem. If so, HVI shall notify the Member that the plan is acceptable.
 - 9.2.8.5.2. A notice of completion shall be provided to HVI. Along with the notice of completion, the Member shall inform HVI how to tell the difference between old and new products on the outside of the carton so they may be procured.
 - 9.2.8.5.3. HVI will normally procure and test a unit after receiving the notice of completion, following procedures similar to the Verification procedures described above, and using Member information to be sure revised product is being tested.
 - 9.2.8.5.4. If the Member does not meet the schedule by providing the total completion information to HVI, the Member's only remaining options are described in clause 9.2.8.6.
- 9.2.8.6. Final resolution of failures. After a model has failed, the failure can be considered finally resolved only after another unit is purchased on the open market and passes the Verification test, or the model is certified at the lower rating obtained in the Verification test, or the model is withdrawn from the market.

- 9.2.9. HVI Directory. HVI will enter appropriate changes to certified ratings into the HVI Directory at its next issuance.
- 9.2.10. Costs of Verification. HVI will bill each Member, in advance and/or afterward, for all verification costs, including purchase, shipping and testing. HVI will add a standard fee for its administrative costs associated with verification.
- 9.2.10.1. The Member, not HVI, is responsible for payment of, or negotiating, any additional or unusual laboratory costs developed because of a need to re-test, test failures, or any dispute with the designated testing laboratory.
- 9.2.11. Repeated verification tests. The preceding describes situations that indicate a need to procure a new unit and repeat a verification test. Among those reasons are: unit damaged in transit, unit is defective or has incorrect part(s), and/or the Member disagrees with the procedure. The need for repeated testing may be determined by HVI and/or the Member. In either case, the Member shall be responsible for associated costs.
- 9.2.12. Verification review. As a normal part of the verification cycle each year, HVI will report the results of the verification as a whole at the next meeting of the HVI Engineering Committee and general membership. HVI will identify the percent of each certified rating achieved in each test. The report will be divided by product category showing the number tested in each. The purpose of the report is to enable Members to assess the overall condition of the HVI verification program.
- 9.2.12.1. Proprietary information will not be disclosed (if less than three Members are in any category, it will be reported as “all other”).

HVI Verification Timeline Chart (Proposed)



24-Aug-06

10. HVI Challenge – Requirements and Procedures

10.1. Requirements of HVI Challenge

- 10.1.1. The purpose of the HVI Challenge is to strengthen the HVI Certified ratings program, and to provide for resolving a documented dispute between HVI Members regarding HVI Certified Ratings. The dispute may involve certified ratings and/or performance, or the presentation of ratings to the marketplace.
- 10.1.2. Procedure for HVI Challenge, below, contains several deadlines. If a challenged Member misses those deadlines, HVI may summarily withdraw the HVI Certification of a model number, notifying both challenger and challenged Member. In such cases, the model number shall be removed from the HVI Directory and HVI shall answer inquiries by stating that the model is not HVI Certified.
- 10.1.3. The HVI Challenge timeline is shown as a chart at the end of this section.
 - 10.1.3.1. The same penalty shall be imposed if the challenged Member chooses to ignore the process.
- 10.1.4. The challenge process is carried out confidentially unless a model number fails a challenge, in which case results may become known as described below.
 - 10.1.4.1. During the normal course of a challenge, neither the challenger nor the challengee shall broadly disseminate information about it or about its existence.
 - 10.1.4.2. In the event a product fails a challenge, that fact may be disseminated upon receipt of the report.
- 10.1.5. Where this section requires that a Member's literature (catalog) be changed, the Member's website shall also be changed. The time allotted for changing the website shall be not more than 15 days.
- 10.1.6. In Procedure for HVI Challenge, below, there are points where HVI may determine it is necessary to conduct a verification test in order to enforce and/or uphold the HVI Certification process. HVI shall identify such points and conduct verification whenever HVI considers it appropriate.

- 10.1.7. The cost of a challenge shall include the procurement costs, transportation costs, laboratory testing fees and HVI administration costs. All of HVI's costs associated with a challenge must be covered.
- 10.1.8. Informal challenges shall be received by HVI, especially with respect to possible misrepresentation of a certified product's performance in literature and/or website. HVI may receive such a challenge in the form of a formal letter from any source. HVI shall investigate and take action to protect its certification program. See also paragraphs 4.19, 4.26, and 4.27.
 - 10.1.8.1. Informal challenges are not required to follow steps of the challenge procedure described in this section.

10.2. Procedure for HVI Challenge

- 10.2.1. When an HVI Member has reason to believe another Member's model number is not meeting its HVI Certified ratings, or the ratings are being misrepresented, the first Member may initiate an HVI challenge.
- 10.2.2. The HVI Representative of the Member company considering a challenge shall contact HVI to verify the certified rating(s) of the model number in question and to get an estimate of the cost of the challenge.
 - 10.2.2.1. At the time of the pre-challenge inquiry the inquiring Member should ask HVI whether the model number is part of a family of models, and if so, request that HVI provide full basic and derived information.
 - 10.2.2.2. If the model number that is the subject of the inquiry is already being challenged by another Member, HVI shall explain the challenge in detail to the inquiring Member's representative, who will be guided by the information, but will not publicize it.
- 10.2.3. After verifying ratings, the representative of the inquiring Member may initiate the challenge by writing a letter to HVI. A challenge is considered to be initiated only when all of the following items are received by HVI:
 - 10.2.3.1. Identification of the challenged model number.
 - 10.2.3.2. Identification of the challenged parameter(s) and the basis for challenging them.
 - 10.2.3.3. Payment deposited with HVI for the estimated cost of the challenge.

- 10.2.4. Within 1 week after receiving a challenge letter, HVI shall notify the challenged Member (challengee) and provide them a copy of the challenger's correspondence.
- 10.2.5. Within 3 weeks after HVI notification of the challenge, the challengee shall respond to HVI in writing, providing the names of at least six outlets where the product may be procured, and choosing one of the following alternatives. (This is the first decision the challenged Member is required to make.)
 - 10.2.5.1. Accept the challenge.
 - 10.2.5.1.1. HVI will proceed with Challenge Testing, described below.
 - 10.2.5.2. Apply for a rating that is sufficiently adjusted to satisfy the challenger.
 - 10.2.5.2.1. HVI shall act as mediator to arrive at a mutually acceptable rating. If not successful in one week, HVI will proceed with Challenge Testing, described below.
 - 10.2.5.3. Withdraw the model number.
 - 10.2.5.3.1. If the challenged Member chooses to withdraw the model number, the Member must immediately cease producing that model and change all literature at the next printing. The model number will be removed from the HVI Directory and inquiries will be answered that the model number is not HVI Certified.
 - 10.2.5.4. Submit a "plan of corrective action" that recognizes the deficiency and corrects the model number's performance so it meets requirements as soon as possible, but in no more than 60 days.
 - 10.2.5.4.1. The challenged Member shall immediately cease producing the model number and inform HVI of the schedule and of how to differentiate between old and new product on the outside of the carton.
 - 10.2.5.4.2. Within 1 week, HVI will forward a copy of the challengee's plan of corrective action to the challenger.

10.2.5.4.3. Within 1 week, the challenger will notify HVI whether or not the response from the challengee is acceptable. If the challenger is satisfied with the corrected rating or the plan of action, and if both the challenged Member and HVI agree, the challenge may be dropped and the unused portion of the challenger's deposit will be returned. If not, the challenge proceeds.

10.2.6. Challenge Testing. Within 3 weeks, HVI shall procure the product, and have it tested at the designated laboratory in accordance with HVI Verification Test procedures. HVI shall notify both parties of results within two days of the test. HVI shall retain a copy of the test report in the product's file and send a copy of the test report and a pass/fail notice to both the challenger and challengee. The test report is confidential and shall not be disseminated by the challenger in any way. (The pass/fail analysis shall be based on the certified rating, not the initial test report.)

10.2.6.1. Pass. If the product is determined to have passed the challenge test, the ratings have been confirmed and are in good standing.

10.2.6.2. Fail. If the challenged product has failed, the model number's ratings, and all products in the basic and derived family are immediately considered probationary. See: Resolution of Challenge Test Failure, described below.

10.2.6.2.1. When ratings are considered probationary, upon inquiry about the model number, HVI shall so state.


10.2.6.2.2. HVI shall publicize the model number(s) of products whose ratings are considered probationary on the next revision of the HVI website directory, and for 60 days thereafter. The definition of "probationary" shall be published on the website whenever probationary ratings are published.

10.2.6.2.3. In the event the challenged Member disputes a test failure based on a laboratory set-up or process, they may ask HVI to order a re-test at that Member's expense.

10.2.6.2.3.1. The challenged Member may request permission to witness the re-test. HVI shall permit such witnessing, coordinate the test timing with the laboratory, and present the challenger the opportunity to witness the re-test also, with the challengee.

- 10.2.7. Resolution of Challenge Test Failure. Within one week, the Member shall choose one of the following actions. (This is the second decision the challenged Member may be required to make.)
- 10.2.7.1. Immediately accept the ratings from the challenge test, mark the product with the new ratings, and change all literature at the next printing.
- 10.2.7.1.1. The challenge test report then becomes the test report for the model number and its family of model numbers.
- 10.2.7.2. Immediately drop the product from the market and modify literature at the next printing.
- 10.2.7.3. Immediately obtain a new certification from HVI, satisfying all requirements, including a new test report and information on how to differentiate between old and new product on the outside of the carton.
- 10.2.7.3.1. If this option is chosen, HVI shall promptly verify performance of the new product through marketplace pickup.
- 10.2.8. HVI shall immediately notify the challenger of the challengee's choice, including the means of differentiating between old and new product, if applicable.
- 10.2.9. Costs. If the product passes the challenge, an invoice of actual costs less initial deposit will be sent to the challenger. If the product fails the challenge test, and/or if repeated tests are considered necessary, the challengee is responsible for costs; a final invoice of actual costs will be sent to the challengee and the challenger's initial deposit will be refunded.

HVI Challenge Timeline Chart



06-Jan-04

11. Maintenance of HVI Publication 920

- 11.1. HVI 920 is the basis for participation in and control of HVI's Certification program, one of its most valuable core processes. Therefore, it is vitally important that it be maintained with painstaking accuracy. On the other hand, it is important to enable constructive changes without unnecessary difficulty.
- 11.2. HVI shall offer the current version of HVI 920 on the HVI website for download in a non-editable (protected) form.
 - 11.2.1. The cover sheet of the publication shall indicate the Edition (year) and Version (date). The version date will relate to the date of publication.
 - 11.2.2. For best service to Members, customers, and consumers, the updated HVI 920 must be available on the website promptly, consistent with the drafting and review(s) required to ensure impeccable accuracy.
- 11.3. Maintenance of this document, and the HVI Certification process, is the responsibility of the Certification Committee.
 - 11.3.1. The Certification Committee and its Chair shall be responsible for managing and enforcing the appropriate drafting, editing and review structure for each change.
 - 11.3.2. The Certification Committee shall submit all substantive changes to the general membership for adoption at a regular meeting, or by letter ballot if deemed necessary.
 - 11.3.3. The magnitude and impact of a proposal to change HVI 920 shall be the basis for determining the appropriate structure for drafting, adopting, and incorporating such change. The appropriate process should be decided as part of considering the change.
 - 11.3.3.1. Substantive changes, especially those that cause significant change in the HVI Certification process, shall be processed and communicated carefully. Such changes may require approval by one or more groups, shall be approved by the HVI Certification Committee, and shall be finally adopted by the general membership.
 - 11.3.3.2. Very small changes or editorial explanations, as examples, may appropriately go through a simpler process and be incorporated into HVI 920 more promptly.

- 11.4. Presentation of proposals for changes to HVI 920 may be by any HVI Member, by any group of HVI Members, and by any committee of HVI.
 - 11.4.1. A change may be proposed in more than one way. For expeditious adoption, proposals should be as complete as possible in both substance and format. However, a proposal may be presented to HVI staff, who shall direct it appropriately. Alternatively, the Member may request an agenda item to present a proposal. In any case, the proposal must be presented with sufficient specificity for consideration.
 - 11.4.2. In response to a legitimate request, HVI will provide HVI 920 in unprotected MS Word for developing a proposal(s). The individual developing the proposal is encouraged to incorporate the proposal, in complete detail, into the appropriate sections and paragraphs of HVI 920 using an 'add and delete' format (e.g., MS Word 'Track').
 - 11.4.3. When it is not practical to provide a proposal in complete format, the other methods may be used.
 - 11.4.3.1. A proposal may be written with thoroughness, but not in format, and adopted as presented or with minor amendment.
 - 11.4.3.2. If a proposal not written in HVI 920 format, or not thorough, is adopted, the Certification Committee Chair shall direct the drafting, approval, and incorporation of the final language into HVI 920.
 - 11.4.3.3. When appropriate and convenient, a thoroughly drafted proposal may be provided along with HVI 920 as a temporary supplement until it is drafted into the sections and paragraphs of HVI 920.
- 11.5. Periodically the Certification Committee may decide that a new edition of HVI 920 is in order. A new edition offers the opportunity for general revision and editing without changing the substance of the provisions in the publication.
- 11.6. Additional HVI Certification programs may be developed and added to this procedure upon adoption by the product group, the Certification Committee, and the general membership.
- 11.7. The appendices to this procedure are considered to be part of the procedure and revisions of appendices shall be administered the same as revisions of the body of the procedure.
- 11.8. Each new Edition of HVI 920 will be registered for US copyright.

APPENDIX I. PRODUCT CATEGORIES, TOLERANCES, REQUIREMENTS

Note: Requirements of a general nature are described in this Appendix. Particular requirements for specific product categories are described in the appendices that apply to those categories. If requirements for specified items such as testing, ratings, and tolerances in a category's appendix differ from the general requirements in this appendix, the requirements of the category appendix shall take precedence.

Standard HVI Product Categories

The following are the standard product categories for the HVI Directory and for certification requirements. Members may occasionally, with HVI permission and if there is good reason, use additional descriptions as subsets to the main product categories.

Tabulated after the product categories are the appendices describing specific requirements, and the verification year for the category.

<u>HVI Product Category</u>	<u>Appendix</u>	<u>Verification Year</u>
Bathroom Exhaust Fans including Combination Units	II	Even
Downdraft Kitchen Exhauster (incl. non-powered ¹)	II	Even
Duct Termination Fittings	VII	Odd
Energy Recovery Ventilators*	III	Odd/Even
Fresh Air Inlets	V	Even
Heat Recovery Ventilators*	III	Odd/Even
Integrated Supply and Exhaust Ventilators	VI	Even
Inline Fans	II	Odd
Kitchen Fans	II	Odd
Kitchen Range Hoods (including non-powered ¹)	II	Odd
Other Room Exhaust Fans	II	Even
Power Attic Ventilators	II	Odd
Range Hood Power Units ²	II	Odd
Remote Exterior Mounted Ventilators	II	Odd
Static Vents	V	Even
Whole House Comfort Ventilators	II	Odd

**Approximately fifty percent of HRV/ERV manufacturers will be subject to product verification for HRVs and ERVs each year; as a general rule, each manufacturer will be selected for HRV/ERV verification once in a two-year period.*

¹*Non-powered kitchen ventilators are to be tested for Combination Rating. See HVI 915 and HVI 916 for testing, and Appendix IV of this publication for rating.*

²*HVI certifies Range hood power units only in conjunction with a non-powered kitchen ventilator.*

Verification Grouping

Certain product categories may be grouped by HVI before randomly selecting the verification models. After grouping, HVI may select from the group, following the procedure described in Section 9. "Verification", rather than the category. Groups shall be as follows:

- Downdraft kitchen exhausters and Other room exhaust fans
- Energy recovery ventilators, Heat recovery ventilators, and Duct termination fittings.

Tolerances for Verification and Challenge

Airflow rating tolerance. All products shall achieve a minimum of 90% of their HVI Certified airflow rating. Exceptions, if any, are found in the Appendix for the product category.

Sound rating tolerance. All products shall produce not more than 110% of sound rating plus 0.25 sones. Exceptions, if any, are found in the Appendix for the product category.

Energy rating tolerance. (Energy to run fan.) All products shall operate at not more than 110% of their HVI Certified energy rating to run the fan. Exceptions, if any, are found in the Appendix for the product category. (This is not the same as the energy factors for Heat/Energy Recovery Ventilators, described under Verification in Appendix III.)

Units of Measure

Units of measure in this procedure are the inch-pound (IP) system. Values in IP units may be converted to International Standard (SI) units using conversions found in the ASHRAE Handbook of Fundamentals, chapter on Units and Conversions. Members shall list HVI Certified ratings in IP units as described herein. In addition, Members may list HVI Certified ratings in SI units using the following "rule of thumb" conversions for the units listed below.

Rounding: Before IP ratings are converted to SI, they are already rounded and additional rounding is not required. Section 7 describes requirements for rounding HVI Certified ratings for presentation.

Static pressure: 1 inch of water may be converted to 250 Pascals for values of one inch or less.

Airflow: one cubic foot per minute airflow may be converted to 0.47 liters per second for values of 1000 cfm or less.

Energy: Watts are used for both systems.

For testing and rating conducted under HVI Airflow and Sound Procedures, the primary units are IP and may be converted to SI as described. For testing and rating conducted under procedures based on CSA 439, the primary units are SI and may be converted to IP as described.

The Normalized Curve for Airflow Ratings

HVI Certified airflow ratings are based on precise airflow testing, and each product category has an HVI specified basic rating point static pressure. For certain categories, there are additional optional or required rating points (see the applicable category appendix). For the basic rating point, airflow is rounded down to the nearest ten cfm, as described in Section 7. For additional airflow ratings, a normalized curve is used. This abbreviated overview of the uses of a normalized curve serves as a foundation for the following description of creating and using it. Other details related to the Normalized Airflow Curve are described in other parts of this publication, including Section 4, and the appendices for each category.

Constructing a normalized airflow curve begins with the normalized airflow curve ratio (NCR). The NCR is the 3-decimal expression (less than, or equal to, one) of the ratio between the airflow rating and the test report airflow, both at the same basic static pressure rating point. The airflow at each test point is normalized when it is multiplied by the NCR, to create the normalized curve. The normalized curve for a fan will pass exactly through the rating point, and will pass through the same static pressure at zero airflow as the test curve.

The resulting curve is used for additional HVI Certified rating points described in the appendices. The curve may also be represented as being in accordance with HVI procedures for non-certified performance information.

Certification and Presentation of Energy (To Run Fan) Ratings

An HVI Member, at their option, may apply for certification of Energy to Run Fan. HVI shall issue certification of such rating if requirements are met. Also at the Member's option, such rating may be shown in the HVI Directory. Exception: Energy to run fan (watts) must be certified and published in the HVI Certified Products Directory to maintain eligibility for the Energy Star Program. It is not required that Members certify all products in a category for Energy to Run Fan.

If Members represent the energy to run their HVI Certified products in conjunction with the HVI Label and/or Logo, and in conjunction with HVI Certified performance ratings, that data shall be HVI Certified Energy to Run Fan ratings, and such ratings shall be presented in accordance with HVI requirements and procedures.

APPENDIX II. SPECIAL REQUIREMENTS – EXHAUST PRODUCTS

Product Categories Included

Product categories whose requirements are covered by this Appendix (II) are generally mechanical exhaust products, and are listed in Appendix I. The first part of this appendix describes requirements that apply broadly to the categories; following in the second part are particular requirements for some product categories.

Required Certification

Airflow. All Appendix II products shall be certified for airflow.

Sound. All Appendix II products shall be certified for sound level.

Exception: Sound is not required for the following products because no HVI sound certification program currently exists.

- Power attic ventilators
- Remote exterior mounted ventilators (except in combination with non-powered kitchen ventilators)
- Whole house comfort ventilators
- In-line fans (except in combination with non-powered kitchen ventilators)

Energy to run fan. Optional for all products in Appendix II.

Rating Points

Ducted products. Ducted Appendix II products shall have basic HVI airflow ratings at a fan static pressure of 0.1 inch, if the product has one duct, e.g., bathroom exhaust fans. Additional optional and required rating points are described in this appendix. Exception: In-line fans shall have basic ratings at a fan static pressure of 0.2 inch (including inlet and outlet ducts).

Direct discharge (non-ducted) products. Direct discharge products exhaust directly to the outside, without ductwork, shall be rated at 0.03 inch static pressure. Additional ratings for these fans are not anticipated. Exception: Whole house comfort ventilators - see below. Included are:

- Power attic ventilators (both roof mounted and gable mounted)
- Direct discharge types of Kitchen fans, Other room exhaust fans, etc.

Particular Requirements for Certain Product Categories

In-line fans – Particular requirements

The required basic rating point is 0.2 inches of water. At 0.2 inches of water, round down to the nearest 10 cfm for the basic rating. Two additional rating points, at static pressure greater than 0.2 inches of water, may be certified at the Member's option. For those points, create a normalized curve and round down to the nearest whole number. See also Section 4, "General Requirements". When an in-line fan is offered for use with non-powered kitchen ventilators, additional requirements are described in Appendix IV, Combination Rating.

Whole House Comfort Ventilators – Particular requirements

The basic rating point is 0.1 inches of water, even though not ducted, because they are expected to overcome the resistance of attic outlet vents. They are tested and certified using the smallest shutter recommended by the Member, and at the minimum distance between fan and shutter recommended by the Member. (See *HVI Publication 916, HVI Airflow Test Procedure*.)

Power Attic Ventilators – Particular requirements

If a gable mounted type power attic ventilator is sold with a louver, it shall be tested and certified with that louver. If sold without a louver, it shall be tested and certified with the "standard HVI louver", described in the HVI 916. For an additional rating, units may also be tested with a specific model of louver or shutter, and it shall be identified in the Member's literature. Power attic ventilators are rated for airflow at 0.03 inches of water.

Kitchen Range Hoods – Particular requirements

Two additional rating points, at static pressure greater than 0.1 inches of water, may be certified at the Member's option. For those points, create a normalized curve and round down to the nearest whole number. See also Section 4, "General Requirements".

Separate range hood power packs for mounting in a hood shall be tested and certified using one of the Member's recommended hoods. If the manufacturer makes no hood for use with the power pack, a representative hood from another source, or a representative mock-up, may be used.

Range hoods may optionally be tested and certified at "working speed" in addition to the maximum speed basic certification. In general, working speed is considered low speed for a two-speed hood, and for a multiple- or variable-speed hood, it is a low speed near 100 cfm. The specific procedure for working speed certification of a hood is found in the HVI 916. Tolerance for working speed airflow is $\pm 15\%$ of rating. Tolerance for working speed sound is the same as other sound ratings.

Remote Exterior Mounted Ventilators – Particular requirements

When a product in this category is offered for use with non-powered kitchen ventilators, additional requirements are described in Appendix IV, Combination Rating.

APPENDIX III. SPECIAL REQUIREMENTS – HEAT AND ENERGY RECOVERY VENTILATORS

HVI certifies several parameters for ducted HRVs and ERVs; there is currently no program for non-ducted versions. Two-duct ceiling/wall insert HRV and ERV products are tested for energy in accordance with these procedures.

HVI Certification of these products is based on testing both airflow and energy recovery performance in accordance with CAN/CSA C439 (-00), *Standard Laboratory Methods of Test for Rating the Performance of Heat/Energy-Recovery Ventilators*, herein referred to as CSA C439. This publication and this specific appendix describe exceptions to CSA C439.

The HVI testing and rating program for Appendix III products is more prescriptive than CSA C439; however there is no HVI testing document for the categories in this appendix. Therefore, this appendix records information and requirements that might normally be expected to be found in an HVI test procedure rather than this type of document.

Certified Ratings

The entire HVI Certified HRV/ERV Design Specification Sheet is considered HVI Certified.

Airflow ratings shall be either test data rounded to the nearest whole number, or shall be test data rounded down to tens, at the Member's option. "Rated airflow" is chosen for energy performance ratings, and shall be published.

Energy performance ratings shall be rounded down to the nearest whole percentage number.

All test conditions not prescribed, including the use of accessories, defrost connection, auxiliary controls, and additional rating point(s) shall be reported with the test results.

HVI currently has no sound certification program for Appendix III products. Two-duct ceiling/wall insert HRV and ERV products are tested for energy in accordance with C439 using pickup boxes on the grille openings. They are tested for airflow and sound in accordance with HVI 916 and 915.

Any HRV or ERV in a Base and Derived family of products, for Verification and Challenge, must meet the highest certified rating for the entire Base and Derived family.

Tolerances for Verification and Challenge

Maximum Net Supply Air Flow: 85% minimum
Maximum Net Exhaust Air Flow: 85% minimum
Rated Air Flow: Not to be verified or challenged

Energy recovery parameters: 90% minimum
Energy (electricity) to run fans: 115% maximum

General Requirements

Members making application to HVI for certification of an HRV or ERV shall submit to HVI the standard "HVI Certified HRV/ERV Certified Product Specification Sheet". The required blank forms and assistance completing the forms are available from HVI.

All HRV and ERV products shall be tested and certified for both energy performance and airflow. Airflow and energy performance are separate tests from the same setup.

Maximum airflow as per section 10.3.1 of CSA C439 may be achieved by operating the unit's fan(s) at less than the maximum speed setting, if a speed control is supplied as part of the unit. This may be done to the Member's specifications by adjusting the airflow resistance of the test facility. Additional tests may be done at airflows other than the maximum rated airflow.

Additional test conditions may be tested and published on the HVI Specification Sheet, at the Member's option. Common test points are at -13°F (-25°C) and 95°F (35°C), and 64 and 117 cfm.

Performance Calculations

The following performance calculations are used in place of those in CSA C439. Symbols in the equations are the same as CSA C439 and are defined there.

1. Sensible Heat Recovery (SHR) in the heating mode shall be calculated as:

$$E_{SHR} = \frac{\left[\sum_{i=1}^n M_{si} \times C_p (t_{5i} - t_{1i}) \times \Delta\theta \right] - Q_{SF} - Q_{SH} - Q_C - Q_D - Q_L}{\left[\sum_{i=1}^n M_{max,i} \times C_p (t_{3i} - t_{1i}) \times \Delta\theta \right] + Q_{EF} + Q_{EH}}$$

2. Sensible Heat Recovery (SHR) in the cooling mode shall be calculated as:

$$E_{SHR} = \frac{\left[\sum_{i=1}^n M_{si} \times C_p (t_{5i} - t_{1i}) \times \Delta\theta \right] + Q_{SF} - Q_C - Q_L}{\left[\sum_{i=1}^n M_{max,i} \times C_p (t_{3i} - t_{1i}) \times \Delta\theta \right] - Q_{EF}}$$

3. Total Heat Recovery (THR) in the heating mode shall be calculated as:

$$E_{THR} = \frac{\left[\sum_{i=1}^n M_{si} \times (h_{5i} - h_{1i}) \times \Delta\theta \right] - Q_{SF} - Q_{SH} - Q_C - Q_D}{\left[\sum_{i=1}^n M_{max,i} \times (h_{3i} - h_{1i}) \times \Delta\theta \right] + Q_{EF} + Q_{EH}}$$

4. Total Heat Recovery (THR) in the cooling mode shall be calculated as:

$$E_{THRC} = \frac{\left[\sum_{i=1}^n M_{si} \times (h_{5i} - h_{1i}) \Delta\theta \right] + Q_{SF} - Q_C}{\left[\sum_{i=1}^n M_{max,i} \times (h_{3i} - h_{1i}) \times \Delta\theta \right] - Q_{EF}}$$

Verification Requirements and Procedures

Selection of HRV and ERV Products for Verification:

1. HVI shall maintain a list of all base models that are certified as of January 1 of each year.
2. Any model on the list with a test report on file at HVI that is less than one year old shall be removed from the list.
3. Any model that has a passed verification test on file that is less than five years old shall be removed from the list.
4. Any model with a test report on file that is older than 5 years shall have a duplicate line entered in the list, doubling the probability that it will be selected for verification.
5. Each model on the list from a manufacturer who has had a failure of either verification or challenge test shall have a duplicate entry made on the list for the following two calendar years, doubling the probability that a model from that manufacturer will be selected for verification testing.

6. A random selection process will be used for selecting the first and each subsequent model selected for verification.
7. Unless a special testing frequency is approved by HVI, a Member is normally subject to a verification test once every two years. The effect of the preceding requirements is that if a Member has a certification report less than one year old, or a passed verification test less than five years old, for every certified model, that Member will not be subject to a verification test in that round.

Shipment of Test Unit: When ordering, HVI shall instruct the source to ship the selected unit either on skids or properly crated to the designated verification test laboratory.

Schedule: The designated verification test laboratory shall inform manufacturers of the verification test schedules. Manufacturers must inform the laboratory and HVI if they wish to be present to witness the verification testing. The designated test laboratory shall make every attempt to schedule tests for the convenience of manufacturers who ask to witness the testing. The designated testing laboratory shall notify the manufacturer a minimum of 7 calendar days before commencement of any test.

Receiving Inspection: When each verification test unit arrives at the designated testing laboratory, the laboratory shall inspect the unit for damage, missing components and manufacturing defects. The designated testing laboratory shall notify the manufacturer if any of those problems are detected. The manufacturer shall notify HVI and the laboratory whether or not the damaged unit shall be tested as is. If the unit is not capable of being tested, HVI shall decide to either re-sample the unit or, if possible, permit the manufacturer to repair the unit at the testing laboratory. If HVI authorizes the manufacturer to repair the unit, missing or damaged components shall be replaced out of the manufacturer's stock inventory. The manufacturer shall furnish documentation to HVI and the laboratory that any replacement components are correct standard production parts for the test unit.

Inspection of Test Setups: The designated testing laboratory shall perform all test setups. The manufacturer shall be allowed to inspect the test unit and setup for each test, including airflow, cross leakage, and energy performance, both low temperature and air conditioning. The manufacturer shall be permitted to ensure that the test unit is properly set up, including the proper setting of the unit's controls and that the test installation is in accordance with the manufacturer's instructions. HVI shall be the final authority in the event of differences of opinion between the manufacturer and the laboratory.

Testing: Testing will be conducted in accordance with the testing procedures described for initial HVI Certification.

Test Witnessing: The manufacturer shall be permitted to witness each test including the test data.

Verification Test Failures: If a unit under test experiences a failure within the verification sequence, the designated testing laboratory shall notify HVI before proceeding with the next test in the sequence. HVI shall instruct the laboratory to terminate testing if it is obvious that remaining tests will fail, but will normally instruct the laboratory to continue the test sequence. HVI will notify the manufacturer of the preceding.

If the unit failed due to a component failure, HVI will give the manufacturer the option of furnishing a replacement component for the laboratory to install and then ordering the unit re-tested at the manufacturer's expense. The manufacturer shall furnish verification to HVI that the replaced component is the correct stock replacement for the failed component. All verification test protocol applies to the re-test.

If a model fails verification, and the Member decides to re-test for re-certification, the Member shall provide a new unit directly to the testing lab within 30 days of receiving notice of the failure. The normal certification procedure is followed, and the model must ultimately be re-certified or withdrawn.

The Certified ratings for models in a base and derived family of HRVs or ERVs may differ, because the Member has the option to de-rate. When testing for Verification and Challenge, if any model in such a family of HRVs and ERVs fails to meet the highest certified rating for models within the family, the entire family is judged to have failed. This is an exception to the rule in Section 6 that applies only to HRV and ERV products.

APPENDIX IV. SPECIAL REQUIREMENTS – COMBINATION RATING

Combination testing for HVI Certified ratings may be done for certain types of products that are incomplete by themselves and are offered with options. Examples include a non-powered model that may be used with more than one power unit model, or vice versa. Combination rating applies to kitchen ventilation products, although it may be possible to expand it to other types. Applicable product types are divided into the powered units and the non-powered units.

Powered units:

- Remote exterior mounted ventilators
- In-line fans
- Range hood power units

Non-powered units (kitchen ventilators):

- Non-powered catalogued range hoods
- Custom range hoods, including site built hoods
- Non-powered downdraft kitchen exhausters

As an exception, requirements for range hood power units intended for non-powered range hoods are described in Appendix II, under Kitchen Range Hoods.

In-line fan requirements are found in Appendix II. Those requirements are not affected by this section. However, when those products are offered for kitchen ventilation applications, this section applies.

Remote exterior mounted ventilator requirements are found in Appendix II. Those requirements are not affected by this section. However, when those products are offered for kitchen ventilation applications, this section applies.

Airflow Testing

Laboratory requirements for combination airflow testing are described in *HVI Publication 916, Airflow Testing Procedure*. That publication describes airflow test plots at the same scale.

HVI Certified Airflow Rating

The performance curves of the two airflow test reports should be drawn to the same scale, size, and zero, in response to a request of the Member arranging for the testing at an HVI designated test laboratory.

Overlay one airflow test curve over the other. To allow for installed duct losses in the accepted HVI manner, the horizontal line representing the HVI static pressure rating point (0.1 or 0.2 inches of water) of the fan curve shall be laid over the line representing zero static pressure of the system curve. The test airflow is found where the fan performance curve crosses the system performance curve.

As with other products, the test airflow value is rounded down to the nearest 10 cfm for the HVI rating point. (An HVI normalized airflow curve may be produced from that number in the same manner as for other products.)

It is possible to apply for several HVI airflow ratings using combination rating. Testing powered units provides an airflow test curve for each; testing non-powered units provides a system curve for each. Using various combinations has the possibility to provide more ratings than the number of tests conducted. (e.g., three power unit tests and three non-powered unit tests can provide nine ratings.)

The Member shall make application to HVI for certification in the normal manner, and HVI shall verify that the curve overlay supports the requested airflow rating. When more than one combination of powered or non-powered products is derived from a set of tests, a note explaining which products were tested shall accompany the rating presented in the Member's catalog.

HVI Certified Sound (Loudness) Rating

HVI requires that hoods be rated for sound. Combination testing cannot be used for sound.

Range hood power unit sound testing is described in Appendix II.

Other combinations shall be sound tested individually, following *HVI Publication 915, Sound Testing Procedure*.

When several airflow ratings result from combination testing, but the Member is confident sound performance does not vary greatly, the Member may test a representative combination for sound. Such a sound rating in the Member's catalog shall be accompanied by a note explaining which products were tested, and stating that other products may vary.

At the Member's option, a product or combination as described above may be sound rated based on test(s) with an acoustic muffler installed between the non-powered kitchen ventilator and the power unit or in-line fan. Such a rating will be in addition to the normal sound rating.

APPENDIX V. SPECIAL REQUIREMENTS – STATIC AND PASSIVE VENTS

Requirements

The products in this category are HVI Certified for Net Free Area in square inches. HVI Certified Net Free Area Ratings are arrived at by airflow test, described in HVI 916. Certification procedures and requirements in this document shall apply where possible. There is no HVI sound certification program for these products.

Products for which this method may be used:

Fresh Air Inlets (through wall, window, etc.)	Under Eave Ventilators
Room-to-room Transfer Registers	Sidewall Ventilators
Roof Ventilators	Ridge Ventilators
Gable End Ventilators	Foundation Ventilators

Testing

Airflow testing shall be in accordance with *HVI Publication 916, Airflow Test Procedure*. As an overview of the procedure described in HVI 916, the products covered in this appendix are tested to determine the volume of airflow through the product as a result of static pressure applied across the product. Net Free Area is calculated from that test by representing the product as a single opening and calculating the area that corresponds to the tested airflow and static pressure.

Certified Ratings

Where airflow ratings are HVI Certified, they shall be rounded down to the nearest cfm at 0.04 inches of water.

Net free area shall be rounded down to the nearest 0.1 square inches.

Tolerances for Verification and Challenge

Airflow and Net Free Area shall be a minimum of 90% of ratings.

APPENDIX VI. SPECIAL REQUIREMENTS – INTEGRATED SUPPLY AND EXHAUST VENTILATORS

Product Categories Included

This appendix describes the requirements for HVI Certification of product(s) named and described as follows:

Integrated Supply and Exhaust Ventilator: An air moving (ventilation) product comprised of factory-assembled elements including one or more fans, with or without heat recovery. The products are used in ducted supply and exhaust systems. A particular characteristic of an integrated supply and exhaust ventilator is that the fresh air supplied to the house is mixed with a certain amount of recycled air from the house. This product category does not include devices that only exhaust stale air or only take in outside air.

Required Certification

Airflow. All Appendix VI products shall be certified for airflow as follows:

Net ventilation airflow, defined as the net quantity of outside airflow supplied to the house.

Gross re-circulation airflow, defined as the total amount of air distributed to the house by the unit under test. Gross fresh airflow and gross exhaust airflow are not HVI Certified, but shall be listed with HVI Certified ratings for design purposes.

Sound. HVI currently has no Sound Certification program for Appendix VI products.

Energy Recovery Performance. Even if Appendix VI products include energy recovery capability, they shall not be HVI Certified for energy performance. As the fresh air supplied to the house is mixed with a certain amount of recycled air from the house, HVI currently has no Energy Recovery Certification program for this category.

Fan(s) Energy Consumption. All Appendix VI products shall be HVI Certified for fan energy consumption in accordance with requirements described in Section 7 of this publication, and in *HVI Publication 916, HVI Airflow Test Procedure*.

Rating Points

The primary rating point shall be 0.2 inches of water.

The second rating point shall be 0.4 inches of water.

Tolerances for Verification and Challenge

Net ventilation airflow shall achieve a minimum of 85% of rating.

Gross re-circulation airflow shall achieve a minimum of 85% of rating.

Watts, fan energy consumption, shall achieve a maximum of 115% of rating.

Testing

Airflow

Airflow rates shall be measured in accordance with CAN/CSA 439(-00), *Standard Laboratory Methods of Test for Rating the Performance of Heat/Energy-Recovery Ventilators*, hereinafter referred to as CSA 439. The following pages describe exceptions to some of the detail and methods in CSA 439.

Definitions:

Gross Fresh Air Supply airflow: airflow supplied from the outside, measured at station 1

Gross Exhaust airflow: airflow exhausted by the unit to the outside, measured at station 4

Gross Recirculation airflow: airflow supplied by the unit to the house, measured at station 2

(For station numbering, see Figure 4 of CSA 439)

Operating point of the unit. Replace Clause 10.3.1 and 10.3.2 of CSA 439 with the following:

The submitter shall provide the testing laboratory with targets of static pressure for each of the four ports. The airflow resistance of the test facility shall be adjusted so that the absolute value of the static pressures at Station 1 is as closely as possible equal to the value at Station 4, and the absolute value of the static pressure at Station 2 is as closely as possible equal to the value at Station 3. Static pressure at station 1 and 2 will be specified by the submitter, but the difference between the static pressure at stations 1 and 2 must be equal to at least 50 Pa for the first test and 100 Pa for the second test. The difference between static pressure at stations 3 and 4 must be equal to at least 50 Pa for the first test and 100 Pa for the second test.

Additional tests may be performed at airflow lower than the maximum rated airflow (for a multi-speed unit, for example). Pressures and airflows will be recorded at the different intermediate speeds on the same system resistance curves used for the highest speed.

Special Test Conditions: Recirculation and Exhaust Air Composition

Supply Ventilation Reduction factor

The Supply Ventilation Reduction factor is a measure of the degree to which the Gross Recirculation airflow is a mix of the outside fresh air and the recycled air from the house. The real amount of fresh air in the Gross Recirculation airflow is:

Net Fresh Air Supply Airflow = $V_S \times F_2$

V_S = Supply Ventilation Reduction factor

F_2 = airflow measured at station 2

Set-up and measurements with the tracer gas shall be performed in accordance with CSA 439.

The Supply Ventilation Reduction factor is determined from the following equations:

$$\text{if } \frac{B_2''}{B_1''} < 0.9 \quad V_S = \frac{B_2''}{B_1''}$$

or

$$\text{if } \frac{B_2''}{B_1''} \geq 0.9 \quad V_S = 1 - \frac{B_2'}{B_3'}$$

V_S = ventilation reduction factor for fresh air

B_1'' = measured concentration of tracer gas at Station 1 in the test described in Clause 8.2.5 of CSA 439

B_2'' = measured concentration of tracer gas at Station 2 (measured in the same units as B_1'') in the test described in Clause 8.2.5 of CSA 439

B_2' = measured concentration of tracer gas at Station 2 (measured in the same units as B_3') in the test described in Clause 8.2.1 of CSA 439

B_3' = measured concentration of tracer gas at Station 4 (measured in the same units as B_2') in the test described in Clause 8.2.1 of CSA 439

Exhaust Ventilation Reduction Factor

The Exhaust Ventilation Reduction Factor is a measure of the degree to which the Gross Exhaust airflow is a mix of the stale air and fresh air. The real amount of stale air in the Exhaust airflow to outside is:

$$\text{Net Stale Air Exhaust Airflow} = V_E \times F_4$$

V_E = Exhaust Ventilation Reduction factor

F_4 = airflow measured at station 4

Set-up and measurements with the tracer gas shall be performed in accordance with CSA 439.

The Exhaust Ventilation Reduction factor is determined from the following equations:

$$\text{if } \frac{B_4'}{B_3'} < 0.9 \quad V_E = \frac{B_4'}{B_3'}$$

or

$$\text{if } \frac{B_4'}{B_3'} \geq 0.9 \quad V_E = 1 - \frac{B_4''}{B_1''}$$

V_E = ventilation reduction factor for exhaust air

B_1'' = measured concentration of tracer gas at Station 1 in the test described in Clause 8.2.5 of CSA 439

B_3' = measured concentration of tracer gas at Station 3 (measured in the same units as B_4') in the test described in Clause 8.2.1 of CSA 439

B'_4 = measured concentration of tracer gas at Station 4 (measured in the same units as B'_3) in the test described in Clause 8.2.1 of CSA 439

B''_4 = measured concentration of tracer gas at Station 4 (measured in the same units as B''_1) in the test described in Clause 8.2.5 of CSA 439

Maximum Net Ventilation Airflow

For certification requirements, the Net Ventilation Air flow is defined as the maximum of the Net Fresh Air Supply airflow or the Net Stale Air Exhaust airflow.

Gross airflows

For each operating point of the unit (50Pa and 100Pa) and for each port, gross airflows obtained from two different tests are available: the first, when the tracer gas is injected at station 1 and the second, when the tracer gas is injected at station 3. As these airflows may be slightly different, the certified gross airflows at the specified operating point of the unit, will be the average of the two test results, at each of the following stations: station 1 (for Fresh Air), station 4 (for Exhaust Air) and station 2 (for Recirculation).

Test Report

Testing agency shall report static pressure and airflow at all 4 ports for each test points, along with the fan speed settings, mixing ratios, and the watts.


If the unit has more than four ports, the manufacturer has to provide the unit modified so that it can be tested with four ports (added to Clause 8.1.1 of CSA 439).

Certified Rating

Requested airflow ratings shall be rounded to the nearest whole integer.

Schematic of the Unit and the Ventilation Reduction factors

The following schematic and description are provided as an aid to understanding and communicating details related to this product category; they are not part of the certification requirements.



X and Y are the airflows exchanged between the exhaust and supply airstreams. The evaluation of the two Ventilation Reduction factors needs two steps. First step, the tracer gas is injected into the airflow before station 1. Tracer gas concentrations are measured at station 1, B''_1 , station 2, B''_2 and station 4, B''_4 . Concentration at station 3 must be null. At the second step, the tracer gas is injected before station 3. Tracer gas concentrations are measured at station 2, B'_2 , station 3, B'_3 and station 4, B'_4 . Concentration at station 1 must be null.

If $\frac{B''_2}{B''_1} < 0.9$, then the Supply Ventilation Reduction factor, V_S is equal to $\frac{B''_2}{B''_1}$. The two tracer gas concentrations are different enough to obtain a good accuracy for V_S . But if $\frac{B''_2}{B''_1} \geq 0.9$ (which means that the Y airflow is low) then $V_S = 1 - \frac{B'_2}{B'_3}$, using data from the second step (tracer gas injected before station 3).

In the same way, the Exhaust Ventilation Reduction factor, V_E , is calculated using these rules:

if $\frac{B'_4}{B'_3} < 0.9$ $V_E = \frac{B'_4}{B'_3}$ (Which means that the X airflow is high enough to use the data from the second step);

if $\frac{B'_4}{B'_3} \geq 0.9$ $V_E = 1 - \frac{B''_4}{B''_1}$ (Which means that the X airflow is rather small, so we have to use data from the first step to have a good accuracy).

Verification

For verification of this product category, use Appendix III, the section entitled Verification Requirements and Procedures.

APPENDIX VII. SPECIAL REQUIREMENTS- DUCT TERMINATION FITTINGS

Duct termination fittings are products that may not have a duct fitting but are normally understood to accept a duct to direct air from an indoor space to the outdoor, outdoor to an indoor space and/or between two indoor spaces. Termination fittings covered under this program shall not allow air to be directed from an interior space to an unconditioned space such as an attic or crawl space.

Requirements

The products in this category are HVI Certified for airflow. There is no HVI sound certification program for these products.

Products Covered

Outdoor Duct Outlets (roof caps, wall caps, eave caps)
Outdoor Duct Inlets

Products Not Covered (reserved for further development of certification program)

Indoor Duct Inlets
Indoor Duct Outlets

Required Certification

All outdoor duct outlets and inlets are to be certified for airflow. Required airflow testing shall be in accordance with *HVI Publication 916, Airflow Test Procedure*. If the manufacturer recommends more than one duct size, all duct sizes must be certified.

Rating Points

All products shall have basic HVI airflow ratings at a static pressure of 0.05 inches of water, rounded down to the nearest whole number. Ten test points approximately evenly spaced shall be measured from approximately zero static pressure to 0.4 inches of water. Two points, however, need to be closely spaced around the .05 rating point to allow for a mathematical (straight-line) interpolation of the rating point.

A minimum certified airflow rating of 10 cfm is required. If the product does not obtain 10 cfm at .05 inches of water, it cannot be certified.

Additional rating points at static pressures other than 0.05 inches of water may be certified at the Member's option. For those points, two test points that are closely-spaced around the intended rating point are used and mathematical (straight-line) interpolation will be used. The resulting rating point will be rounded down to the nearest whole number.

Tolerances for Verification and Challenge

The verification tolerance for all airflow rates shall be a minimum of 90% of rating plus one cfm.